

C.L. "BUTCH" OTTER – Governor RICHARD M. ARMSTRONG – Director DEBBY RANSOM, R.N., R.H.I.T - Chief BUREAU OF FACILITY STANDARDS 3232 Elder Street P.O. Box 83720 Boise, Idaho 83720-0036 PHONE: (208) 334-6626 FAX: (208) 364-1888 E-mail: fsb@ldhw.state.id.us

March 6, 2007

Gary Ghramm, Administrator Sherman Avenue Beehive - Beehive of North Idaho 2100 E Sherman Ave Coeur d' Alene, ID 83814

License #: RC-762

Dear Mr. Ghramm:

On February 8, 2007, a life safety code survey was conducted at Sherman Avenue Beehive - Beehive of North Idaho, Inc. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level(s):

• Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Taylor Barkley, Health Facility Surveyor, Facility Fire, Life Safety, and Construction Program, at (208) 334-6626.

Sincerely,

TAYLOR BARKLEY

Team Leader

Health Facility Surveyor

Facility Fire Safety & Construction Program

TB/slc

Mark Grimes, Supervisor, Facility Fire Safety & Construction Program



C.L. "BUTCH" OTTER, Governor RICHARD M. ARMSTRONG - Director

DEBBY RANSOM, R.N., R.H.I.T - Chief BUREAU OF FACILITY STANDARDS 3232 Elder Street P.O. Box 83720 Boise, Idaho 83720-0036 PHONE: (208) 334-6626 FAX: (208) 364-1888 E-mail: fsb@idhw.state.id.us

February 16, 2007

Dorothy Jones, Administrator Sherman Avenue Beehive - Beehive of North Idaho, Inc 2100 E Sherman Ave Coeur D'Alene, ID 83814

Dear Ms. Jones:

On February 8, 2007, a life safety code survey was conducted at Sherman Avenue Beehive - Beehive of North Idaho, Inc. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying proof of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by March 10, 2007.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK GRIMES

Supervisor

Facility Fire Safety & Construction Program

MG/slc

Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING O1 - ENTIRE BUILDING	(X3) DATE SURVEY COMPLETED
	13R762	B. WING	02/08/2007

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SHERMAN AVENUE BEEHIVE - BEEHIVE OF N  2100 E SHERMAN AVE COEUR D'ALENE, ID 83814					
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY REGULATORY OR LSC IDENTIFYING INFORMA	FULL	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
R 000	Initial Comments  The facility was found to be in substantic compliance with the fire and life safety requirements of the Rules for Residentia Assisted Living Facilities in Idaho. No codeficiencies were cited during the stand fire/life safety survey conducted on Febr 2007.  The surveyor conducting the survey was Taylor Barkley Health Facility Surveyor Facility Fire safety & Construction	al or ore ard ruary 08,	R 000	DEFICIENCY	
ureau of Fac	cility Standards	<del></del>			

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE



## BUREAU OF FACILITY STANDARDS P.O. Box 83720 Boise, ID 83720-0036 (208) 334-6626 fax: (208) 364-1888

Facility Name	Physical Address	Phone Number
Sherman Augure Boehive of North Idaho		(208) 763-3624
Administrator Channel	City	ZIP Code
Survey Team Leader	Survey Type	Survey Date
Taylor Barkley		2-8-7
NON-CORE ISSUES		

	-CORE ISSU		<i>(</i>	·
ITEM #	RULE# 16.03.22	<b>DESCRIPTION</b>	DATE RESOLVED	BFS USE
1.	405.01	A. Facility has an extension cord in use by the computer		66 (180 a) 66 (65 a)
		in the den.		
186				650194
		B. Resident Room # 9 has A multiple electrical Adapter		15 450,000
·	3	in use		
-5,=				14 0 E 0 E
<u>ð.</u>	405,05	A Resident Room # 6 Missing escutcheon plate for sprinkley		52.02.00
		head		
	***************************************			
		B. Resident Room # 9 missing sprinkler escutation plate		
		in the closet,		
				160 (180 (190 ) 160 (180 )
····	*****	c. Resident Room#2 missing escutched plate in		2000
		the bathroom.		
				\$187.5 6.6
	se Required Date	Signature of Facility Representative	Date Signed	
<u>3 · 3</u>	8 - 7	Robert miles	2-8-05	7



## BUREAU OF FACILITY STANDARDS P.O. Box 83720 Boise, ID 83720-0036 (208) 334-6626 fax: (208) 364-1888

Facility Name	Physical Address	Phone Number
Sherman Avenue Beehive of North Administrator	2100 East Sherman Ave.	(208) 763.3624
Administrator		ZIP Code
GARY GHRAMM	Coeur D'Alene	83814
Survey Team Leader	Survey Type	Survey Date
TAYLOR BARKIEU		2-8.7
NON-CORE ISSUES		
ITEM RULE#	DESCRIPTION	DATE BFS

NON-	-CORE ISSU	ES S	
ITEM #	RULE# 16.03.22	DESCRIPTION DESCRIPTION	DATE BFS RESOLVED USE
J	405,05	D. Resident Room # 3 missing escutcheon plate	
54 A		in the bathroom and the closet.	* **
<del></del>			3
×		E. The Liner closet has A one inch by one inch	
		hole in the wall.	# **
,			
		F. The Facility has three Aipe Aenetrations in the crawl space.	
		in the crawl space.	
		*	:
		G. The facility has eight large holes in the	
		G. The facility has eight large holes in the ceiling of the basement.	
<u>3.</u>	410.00	The facility did not conduct At least one fire drill per shift per quarter as required.	
		drill per shift per quarter as required.	
	·	· · · · · · · · · · · · · · · · · · ·	
in the second	se Required Date	Signature of Facility Representative	Date Signed
3~	8-7	Robert mites	2-8-07